



Follow Us

[Products](#) > [Hand Protection](#) > [Electrical Protective Gloves](#)

Electrical Insulated Seamless Gloves

[Back](#)

Article No. JS 1015 | Model No. --

Product Name : Electrical Insulated Seamless Gloves**Details :****ELECTRO SAVIOR** Brand

ISO 9001:2015 Certified Co.

Made as per confirming to IS 4770 / EN 60903 / ASTM 120 D type 1, type 2, type 3, type 4

Approved from ERDA - Electrical Research & Development Association

Accredited by the NABL, Govt. of India & INTERTEK (ASTA), UK

Flow chart of type testing as per IS 4770/1991 is given below

TYPE	Proof (test) Voltage (rms)	Working Voltage (rms) max.
1	5000volts	650 volts
2	10000volts	1100volts
3	17000volts	7500volts
4	25000volts	17000volts
On customer request		
5	33000volts	7500volts
6	33000volts	11000volts




Technology: Modern dipping technology with the moulds as per standards.

Testing:

1. Each & every gloves are tested for proof voltage in in-house laboratory. The certificate for the batch of 100 pairs will be provided.
2. Tested at ERDA - BARODA, INDIA (GOVT. RECOGNISED).
3. Tested at CLI - SION, INDIA (GOVT. RECOGNISED).

Fitting : Special ergonomic design of mould with best dexterity for better gripping.**Puncture :** No Puncture, as each & every pair is tested.**Warranty Information:**

Jayco Safety Products Pvt. Ltd warrants that it's Electro-Saviour Gloves are free from defects in material & workmanship. This limited warranty does not cover any product or component found to have been altered, misused, abused, tampered with or improperly maintained or to have deteriorated due to ageing of any component made of rubber or any other elastomer. The limited warranty does not cover any damage, loss or expense due to damage caused by accident, abuse, improper maintenance, use or misuse of the product.

Storage : Store in original packaging (Opaque packaging used for protection & instructions for use). Do not compact or fold. Do not expose to heat sources (sunlight, radiators, artificial light). Store between 10°C & 21°C.

Inspection : Before each use, carry out a visual inspection. Any puncture or perforation makes the gloves unusable.

Precautions : Do not expose to solvents or chemicals that may cause deterioration. Do not use the glove when damp.

Cleaning : Use water & soap. Dry below 65°C with ambient humidity

Minimum packaging : 1 pair. Opaque & single packaging used for protection & instructions for use. The Electro Saviour gloves, made of latex, are free of allergies (process to clean off protein of latex). In case of allergic reaction to latex please do not use Electro Saviour gloves.

Marking : The date of the electrical test made at the end of production is placed on every glove bag, as well as a lot number to ensure product traceability. Gloves that are used frequently should be tested at intervals less than 6 month. Gloves that are used only occasionally should be tested after each use &, in any case, at intervals of not more than 12 months. Gloves held in stock should be retested at intervals not exceeding 12 months.

Products



- Hand Protection
- Body Protection
- Eye Protection
- Reflective Wear
- Emergency Safety Showers
- Stretchers
- Fix Fall Protection

- Respiratory Protection
- Disposable Personal Protective Wear
- Face Protection
- Helmets
- Foot Protection
- Fall Protection